

DECLARATION OF PERFORMANCE No. PM/CFDM/01/25/1

1.	Unique identification code of the product-type	CFDM	
2.	Products	Dampers – Fire dampers	
	Intended use	Fire safety. To be used in conjunction with partitions to maintain fire compartments in heating, ventilating and air conditioning installations.	
	Technical documentation – product information, instruction for installation and maintenance, safety information	Technical specifications <u>TPM 118/16</u>	
3.	Manufacturer	MANDÍK, a.s. Dobříšská 550, 26724 Hostomice, Czech Republic ID 26718405, tel. +420 311 706 706 mandik@mandik.cz, www.mandik.com	
5.	System of AVCP	System 1	
6.	Harmonised standard	EN 15650:2010	
	Notified body	Notified body No. 1391 PAVUS, a.s., Prosecká 412/74, 190 00 Praha 9 – Prosek	
	Output documents of the notified body	Certificate of Constancy of Performance No. 1391-CPR-2020/0129/O1 Assessment Report of Performance of Construction Product No. P-1391-CPR-2020/0129	

a. Declared performances – fire resistance classification Essential characteristics in accordance with EN 15650:2010, art. 4.1.1				
Fire separating construction, location of the damper	Installation type, installation system	Performance – class of fire resistance		
Solid wall construction – damper in the wall – 100 mm min. wall thickness	Mortar or gypsum ^{1]} Mineral wool with fire protection coating and cement lime plate ^{1]}	As per purchase order EI 120 ($v_e \mapsto 0$) S, or EI 90 ($v_e \mapsto 0$) S, or EI 60 ($v_e \mapsto 0$) S.		
	Ablative Coated Batt 1]	As per purchase order EI 90 ($v_e \mapsto 0$) S, or EI 60 ($v_e \mapsto 0$) S.		
Gypsum plasterboard wall construction – damper in the wall – 100 mm min. wall thickness	Mortar or gypsum ^{1]} Mineral wool with fire protection coating and cement lime plate ^{1]}	As per purchase order EI 120 ($v_e i \leftrightarrow o$) S, or EI 90 ($v_e i \leftrightarrow o$) S, or EI 60 ($v_e i \leftrightarrow o$) S.		
	Ablative Coated Batt 1]	As per purchase order EI 90 ($v_e \mapsto 0$) S, or EI 60 ($v_e \mapsto 0$) S.		
Solid ceiling construction – damper in the ceiling – 150 mm min ceiling thickness	Mortar or gypsum ^{1]} Ablative Coated Batt ^{1]}	As per fire resistance class shown on the purchase order El 90 ($h_o \mapsto 0$) S, or El 60 ($h_o \mapsto 0$) S.		

^{1]} Refer to <u>Technical documentation</u> for the details of the installation type / installation system.

7b.	Declared performances – essential characteristics				
Essential characteristics		Requirements (provisions of the harmonised standard EN 15650:2010)	Performance (lever or class) / Compliance with the requirements		
Nominal activation conditions/sensitivity:		4.2.1.2	Conforms		
- sensing element load bearing capacity		4.2.1.2.2	Conforms		
 sensing element response temperature 		4.2.1.2.3	Conforms		
Response delay (response time): – closure time		4.2.1.3	Conforms		
Opera – cycli	ational reliability: ing	4.3.1, a)	0 cycles – conforms		
- sens	ility of response delay: sing element response to temperature and bearing capacity	4.2.1.2.2 4.2.1.2.3	Conforms		
	oility of operational reliability: ning and closing cycle tests	4.3.3.2	NPD – no performance determined		

The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:

In Hostomice, 2025-01-02

Mgr. Jan Mičan CEO, ppa MANDÍK, a.s.

Declared performances – other characteristics						
Characteristics	Technical standard	Performance (lever or class) / Compliance with the requirements				
Resistance against corrosion	EN 15650:2010, art. 4.2.2 EN 15650:2010, Annexe B	Conforms				