

DECLARATION OF PERFORMANCE No. PM/CFDM/01/25/2

1.	Unique identification code of the product-type	CFDM, CFDM-V	
2.	Products	Dampers – Fire dampers	
	Intended use	Fire safety. To be used in conjunction with partitions to maintain fire compartments in heating, ventilating and air conditioning installations.	
	Technical documentation – product information, instruction for installation and maintenance, safety information	Technical specifications <u>TPM 118/16</u>	
3.	Manufacturer	MANDÍK, a.s. Dobříšská 550, 26724 Hostomice, Czech Republic ID 26718405, tel. +420 311 706 706 mandik@mandik.cz, www.mandik.com	
5.	System of AVCP	System 1	
6.	Harmonised standard	EN 15650:2010	
	Notified body	Notified body No. 1391 PAVUS, a.s., Prosecká 412/74, 190 00 Praha 9 – Prosek	
	Output documents of the notified body	Certificate of Constancy of Performance No. 1391-CPR-2025/0010 Assessment Report of Performance of Construction Product No. P-1391-CPR-2025/0010	

	Declared performances – fire resistance classification Essential characteristics in accordance with EN 15650:2010, art. 4.1.1		
Fire separating construction, location of the damper	Installation type, installation system	Performance – class of fire resistance ^{2] 3]}	
Solid wall construction – damper in the wall – 125 mm min. wall thickness	Mortar or gypsum 1]	EI 120 (v _e) S [V/H]	
Solid wall construction – damper in the wall	Mortar or gypsum 1]	EI 90 (v _e) S [V/H], EI 60 (v _e) S [V/H]	
– 100 mm min. wall thickness	Ablative Coated Batt 1]	El 90 (v _e) S [V/H]	
	2 to 4 dampers in one installation opening – mortar or gypsum ^{1]}	EI 60 (v _e) S [V/H]	
Gypsum plasterboard wall construction – damper in the wall – 125 mm min. wall thickness	Mortar or gypsum 1]	EI 120 (v _e) S [V/H]	
Gypsum plasterboard wall construction – damper in the wall	Mortar or gypsum 1]	EI 90 (v _e) S [V/H], EI 60 (v _e) S [V/H]	
– 100 mm min. wall thickness	Ablative Coated Batt 1]	El 90 (v _e) S [V/H]	
	2 to 4 dampers in one installation opening – mortar or gypsum ^{1]}	El 60 (v _e) S [V/H]	
Solid ceiling construction - damper in the ceiling - 150 mm min ceiling thickness	Mortar or gypsum 1]	EI 90 (h _o) S [H], EI 60 (h _o) S [H]	

- 1] Refer to <u>Technical documentation</u> for the details of the installation type / installation system.
- 2] Fire resistance class markings in accordance with Commission Regulation (EU) 2024/1681
- 3] Depending on the required fire resistance, it is necessary to use a damper type with the corresponding fire resistance.

7b.	Declared performances – essential characteristics			
Essential characteristics		Requirements (provisions of the harmonised standard EN 15650:2010)	Performance (lever or class) / Compliance with the requirements	
Nominal activation conditions/sensitivity:		4.2.1.2	Conforms	
- sensing element load bearing capacity		4.2.1.2.2	Conforms	
 sensing element response temperature 		4.2.1.2.3	Conforms	
Response delay (response time): – closure time		4.2.1.3	Conforms	
Operational reliability: – cycling		4.3.1, a)	50 cycles – conforms	
Dura	bility of response delay:	4.2.1.2.2	Conforms	
 sensing element response to temperature 		4.2.1.2.3		
and I	oad bearing capacity			
	bility of operational reliability: ening and closing cycle tests	4.3.3.2	NPD – no performance determined	

The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:

In Hostomice, 2025-25-03

Mgr. Jan Mičan CEO, ppa MANDÍK, a.s.

Declared performances – other characteristics					
Characteristics	Technical standard	Performance (lever or class) / Compliance with the requirements			
Resistance against corrosion	EN 15650:2010, art. 4.2.2 EN 15650:2010, Annexe B	Conforms			
Application with no ducting (type CFDM-V)	EN 1366-2:2015 art. 6.2.7	Conforms			
Damper blade tightness	EN 1751:2024	Class 2			